



Certificate of Compliance

Certificate: 1052729 (LR 112964-4)

Master Contract: 189705

Project: 2529481

Date Issued: July 12, 2012

Issued to: Socomec S.A.

rue de Westhouse 1
BP 10
Benfeld Cedex, 67235
France
Attention: Elodie Wagner

The products listed below are eligible to bear the CSA Mark shown



Patrick Quinty

Issued by: Patrick Quinty, Eng.

PRODUCTS

CLASS 4651 02 - SWITCHES - Dead-front (Open Type)

Fused load break switches and non-fused load break switches, open type, for use in industrial control equipment. Certified as disconnecting switches. External Frontal operation mechanism, 3 or 4 pole.

Part A: Non-fusible switches, Series SIRCO 400 A and 600A, followed by suffixes, 600V ac max, 250V dc max.

Reference	Cat. No. 3 pole	4 pole
SIRCO 400A	27003040	27004040
SIRCO 600A	27003060	27004060
SIRCO V 400A	27003039	27004039

Part B: Non-fusible switches, Series SIRCO 400A, 600A, 800 A, 1000 A and 1200 A, 600V ac max.

Reference	Cat. No. 3 pole	4 pole
SIRCO 400A	270S3040	
SIRCO 600A	270S3060	



Certificate: 1052729 (LR 112964-4)

Master Contract: 189705

Project: 2529481

Date Issued: July 12, 2012

SIRCO 800A 270S3080

SIRCO 800A 27003080 27004080

SIRCO 1000A 27003100 27004100

SIRCO 1200A 27003120 27004120

Part C: Fusible switches, Series FUSERBLOC J 600 A and L 800 A, 600V ac max.

Reference	Cat. No. 3 pole	4 pole	Cat. No 2 pole
FUSERBLOC J 600A	37123060	37126060	
FUSERBLOC L 800A	37123080	37126080	
FUSERBLOC J 600A	38503060	38506060	38502060
FUSERBLOC L 800A	38503080	38506080	38502080

Part D: Fusible switches, Series FUSERBLOC J 400 A, 600V ac max, 250V dc max.

Reference	Cat. No. 3 pole	4 pole
FUSERBLOC J 400A	37103040	37106040
FUSERBLOC J 400A without test position	37123040	37126040

Part E: Accessories, shorting links for use with Cat. No. FUSERBLOC J60A, J100A, J200A, J400A, J600A and L800A.

Reference	Cat. No.
Shorting links J 60A	37999006
J 100A	37999010
J 200A	37999020 - 37998020 - 37997020
J 400A	37999040
J 600A and L 800A	37999080

Part F: Auxiliary contact holder for use on Cat. No. SIRCO 400A, SIRCO 600A, SIRCO 800A, SIRCO 1000A, SIRCO 1200A.

Reference	Cat. No.
Auxiliary contact holder	39990720

Notes:



Certificate: 1052729 (LR 112964-4)

Master Contract: 189705

Project: 2529481

Date Issued: July 12, 2012

The switches SIRCO 800A (27003080, 27004080) and SIRCO1200A (27003120, 27004120) may be provided with auxiliary contacts Cat. Nos. 27990021, 27990022

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 4-04 - Enclosed Switches

CSA-C22.2 No. 14-10 - Industrial Control Equipment

T.I.L. No. D-29 - Interim Certification Requirements for Disconnect Switches Incorporating Button Contacts